


TEST REPORT

Accredited by NABL (Chemical & Biological)

Report No :	ECI-WA-2023/08/115	Report Date :	17.08.2023
Customer Name & Address	M/s. Dolphin Elite School (CBSE) Bypass Road, Ponmeni, Madurai-625010.		
Customer Reference :	IWO Date : 11/08/2023	Sample Reference No :	ECI-WA-2023/08/115
Sample Drawn By :	ECI	Sample Received On :	11.08.2023
Sample Collected Date :	11.08.2023	Test Commenced On :	11.08.2023
Qty of Sample Received :	2 L	Test Completed On :	17.08.2023
Sample Description :	Water	Sampling Method :	IS 3025:Part 01 & IS 1622
Sample Mark:	Bore Well Water		


S.No	PARAMETERS	UNITS	RESULTS	TEST METHOD
Chemical Parameters:				
1.	Calcium(as Ca)	mg/L	95	IS 3025:Part 40
2.	Chlorides(as Cl)	mg/L	250	IS 3025:Part 32
3.	Electrical Conductivity (EC) @ 25°C	µmhos/cm	1320	IS 3025:Part 14
4.	Iron (as Fe)	mg/L	BDL (DL= 0.01)	IS 3025 Part 53
5.	Lead(as Pb)	mg/L	BDL (DL = 0.01)	IS 3025 Part 47
6.	Magnesium (as Mg)	mg/L	33	IS 3025 Part 46
7.	pH Value @ 25°C	--	7.4	IS 3025:Part 11
8.	Phenolphthalein Alkalinity (as CaCO ₃)	mg/L	Nil	IS 3025:Part 23
9.	Sulphates (as SO ₄ ²⁻)	mg/L	114	IS 3025 Part 24
10.	Total Alkalinity (as CaCO ₃)	mg/L	98	IS 3025 Part 23
11.	Total Dissolved Solids(TDS) @ 105°C	mg/L	858	IS 3025:Part 16
12.	Total Hardness(as CaCO ₃)	mg/L	327	IS 3025 Part 21
13.	Total Suspended Solids(TSS) @105°C	mg/L	<1.0	IS 3025 Part 17
14.	Turbidity	NTU	< 0.5	IS 3025:Part 10
Microbiological Parameters:				
15.	Escherichia coli(MPN)	MPN/100ml	< 2.0	IS: 1622
16.	Total coliform(MPN)	MPN/100ml	11	IS:1622

<--- End of Report --->

 Verified By 

 Remarks : NA – Not Applicable
 BDL –Below Detectable Limit, DL – Detectable Limit

 For ENVIRO CARE INDIA PRIVATE LIMITED
 (Laboratory Division)


 Authorized Signatory


43, 2nd Street, Harvey Nagar, Arasaradi, Madurai - 625 106. Tel : +91 452 4355103

- Note :**
- The results relate only to this item tested.
 - Any correction not attested shall invalidate this report.
 - Report shall not be reproduced anywhere except in full and in the same format without the permission of the laboratory.
 - Unless informed by customer, the test items will not be retained for more than 15 days from date of issue of test report.
 - Total liability of our laboratory is limited to the invoice amount.
 - Any dispute arising out of this report is subjected to Madurai Jurisdiction Only.

